

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0078:167

Page 1 of 1

**CATEGORY:** Control Units (Non High-Rise)

**LISTEE:** ADEMCO, 165 Eileen Way, Syosset, NY 11791  
Contact: David Kalmus (516) 921-6704

**DESIGN:** Model 7720ULF control unit. Suitable for use with waterflow detectors, pull stations and supervisory switches. Unit consists of six 2-wire zones and two 4-wire zones. Basic system:

7720ULF	Control Unit
ADEMCO Model 712BNP	Battery
ADEMCO Model 7620TR	Transformer
ADEMCO Model 7720P	Programmer

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.  
\*Also suitable for central station service when installed and registered the 7720ULF with the network. The unit shall transmit alarm, supervisory, and trouble signals to at least two receivers. The central station service company shall be UL listed.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a fire alarm control unit for use with separately listed compatible indicating devices. This unit is intended for use with System Sensor's Models \*2112/24S and 2112/24TS 4-wire smoke detectors (CSFM Listing No. 7272-1209:187). This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:** This unit is NOT a Digital Alarm Communicator Transmitter (DACT).



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager